

REPORT

POWER CONSUMPTION

CIBC
7125 WOODBINE AVE, MARKHAM ON



REPORT


POWER CONSUMPTION

Project
 Client: BLJC
 Portfolio: CIBC
 Facility: 7125 Woodbine Ave
 Date of Report: Dec 3, 2009

Zone	Energy Consumed	Savings (To date)
METERED SECTION	388 kWh	71.5%


 Energy Saved (kWh)
000973



 Trees
000017


 Vehicles
000000


 Green House Gas Saved (KG)
000700

Average Daily Power Consumption (Pre-Installation vs. Post Installation of Fifth Light LMS)

Metered Data from Pre Installation Overlaid on Metered Data from Post Installation



Post Installation Date Range: Nov. 25 - Dec. 2 2009



CONTACT INFORMATION

FOR SALES & TECHNICAL SUPPORT
PLEASE CALL OUR TOLL FREE NUMBER:
1 (866) 323.0097

OR EMAIL US AT:
SALES@FIFTHLIGHT.CA
SERVICE@FIFTHLIGHT.CA

CORPORATE OFFICE

1155 NORTH SERVICE RD W. UNIT 7
OAKVILLE, ONTARIO
L6M 3E3 CANADA

TO CONTACT OUR CORPORATE OFFICE:
1 (905) 469.2142

OR EMAIL US AT:
INFO@FIFTHLIGHT.CA